

Response to Heritage Victoria questions of April 2026

Thank you for the request for 2 further clarifications.

Re the solar cell mounting brackets, please find the attached document, Clenergy PV ezRack Mounting System, that contains all required information on the mounting brackets.

These brackets are made in NZ and comply with NZ and Australian Standards. They are used extensively across Australia.

Re your second request regarding upgrading the U/G single phase cable to 3 phase cable, the current single phase cable from the meter board to the station building is laid in conduit.

The current plan is to use the existing single phase cable to pull the 3-phase cable back through the existing conduit. There are pits along the cable run which will help pull the 3-phase cable through. We do not believe expensive excavation is required.